HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY I.D.#: 6E-22-A-29
PROPERTY RECORDED:
COUNTY: IREDELL

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: C. DOUGLAS MADISON OWNER: AGENT: ✓ PHONE: 873-0521
ADDRESS: 1805 SAPPHIRE ROAD APPLICATION DATE: 10/20/99 DATE EVALUATED: 10/20/99
STVL, NC 28677 PROPOSED FACILITY: 3 BR HOUSE
PROPERTY SIZE: 0.3999 AC
LOCATION OF SITE: #29 CANTERBURY II
WATER SUPPLY: On-Site Well ___ Comm. Well ___ Public ___ Other ✓ EVAL. METHOD: Auger Boring ✓ Pit ___ Cut ___

PROFILE #	.1940 LANDSCP POS./ SLOPE %	HORIZON DEPTH (IN.)	.1941 (a)(1) TEXTURE	.1941 (a)(2) STRUCTURE	.1941 (a)(3) MINEROLOGY	
1	L 6%	0-48	C	SBK	1:1 / FI / FR	.1942 WETNESS CONDITION 5 .1943/.1956 SAPROLITE 5 .1944 RESTRICTIVE HORIZON 5 .1948 PROFILE CLASSIFICATION PS PROFILE LTAR 0.35 GPD/FT²
2	L 6%	0-48	C	SBK	1:1 / FI / FR	.1942 WETNESS CONDITION 5 .1943/.1956 SAPROLITE 5 .1944 RESTRICTIVE HORIZON 5 .1948 PROFILE CLASSIFICATION PS PROFILE LTAR 0.35 GPD/FT²
3						.1942 WETNESS CONDITION .1943/.1956 SAPROLITE .1944 RESTRICTIVE HORIZON .1948 PROFILE CLASSIFICATION PROFILE LTAR
4						.1942 WETNESS CONDITION .1943/.1956 SAPROLITE .1944 RESTRICTIVE HORIZON .1948 PROFILE CLASSIFICATION PROFILE LTAR
5						.1942 WETNESS CONDITION .1943/.1956 SAPROLITE .1944 RESTRICTIVE HORIZON .1948 PROFILE CLASSIFICATION PROFILE LTAR

AVAILABLE SPACE (.1945) S SITE CLASSIFICATION (.1948): PS SITE LONG-TERM ACCEPTANCE RATE: 0.35 GPD/FT²
OTHER FACTORS(.1946) NONE SYSTEM TYPE CONV. GRAVITY PPPS REPAIR
EVALUATED BY: S. HEDRICK OTHER(S) PRESENT: TERRY O'BRIEN, DICK CRANDALL, RIC CHRISTY
COMMENTS:

DRAFT