HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY I.D.#: 6K 22 A 16
PROPERTY RECORDED:
COUNTY: IREDELL

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

873-0521
APPLICANT: C.D MADISON OWNER: /AGENT: PHONE: 871-1536 (c40)
ADDRESS: 1805 SAFRIET RD APPLICATION DATE: 6-19-95 DATE EVALUATED: 6-23-95
STATESVL, NC 28677 PROPOSED FACILITY: 3 BR SPLIT LEVEL HOUSE
PROPERTY SIZE: ~100' x 150'
LOCATION OF SITE: CANTERBURY #16
WATER SUPPLY: On-Site Well___ Comm. Well___ Public___ Other___ EVAL. METHOD: Auger Boring___ Pit ✓ Cut___

PROFILE #	.1940 LANDSCP POS./ SLOPE %	HORIZON DEPTH (IN)	.1941 (a)(1) TEXTURE	.1941 (a)(2) STRUCTURE	.1941 (a)(3) MINEROLOGY	
1	L 15%	0-10	L	GR	1:1 / FP	.1942 WETNES CONDITION S
		10-40	C	SBK	1:1 / FI	.1943/.1956 SAPROLITE S
		40-72"	SiC	WSBK MICACEOUS	1:1 / FI	.1944 RESTRICTIVE HORIZON S
						.1948 PROFILE CLASSIFICATION PS
						PROFILE LTAR 0.3
2	L 15%	0-10	L	GR	1:1 / FR	.1942 WETNES CONDITION S
		10-48+	C	SBK	1:1 / FI	.1943/.1956 SAPROLITE S
						.1944 RESTRICTIVE HORIZON S
						.1948 PROFILE CLASSIFICATION PS
						PROFILE LTAR 0.3
3						.1942 WETNESS CONDITION -
						.1943/.1956 SAPROLITE -
						.1944 RESTRICTIVE HORIZON -
						.1948 PROFILE CLASSIFICATION -
						PROFILE LTAR -
4						.1942 WETNESS CONDITION -
						.1943/.1956 SAPROLITE -
						.1944 RESTRICTIVE HORIZON -
						.1948 PROFILE CLASSIFICATION -
						PROFILE LTAR -
5						.1942 WETNESS CONDITION -
						.1943/.1956 SAPROLITE -
						.1944 RESTRICTIVE HORIZON -
						.1948 PROFILE CLASSIFICATION -
						PROFILE LTAR -

AVAILABLE SPACE (.1945) S SITE CLASSIFICATION (.1948): PS SITE LONG-TERM ACCEPTANCE RATE: 0.3 GPD/FT²
OTHER FACTORS(.1946) NONE SYSTEM TYPE CHAMBERED GRAVITY (PUMP PRESSURE)
EVALUATED BY: S. HEDRICK OTHER(S) PRESENT: DICK CRANDALL & TERRY O'BRIEN
COMMENTS:

DRAFT

0 0 1 2 8