HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY I.D.#: CITY 6K-22A-12
PROPERTY RECORDED:
COUNTY: IREDELL

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: C. Douglas MADISON OWNER: ~~AGENT~~: ✓ PHONE: 873-0521
ADDRESS: 1805 SAFRIET RD APPLICATION DATE: 9/30/99 DATE EVALUATED: 9/30/99
STATESVILLE, NC 28677 PROPOSED FACILITY: 3BR HOUSE
PROPERTY SIZE: 100 x 150
LOCATION OF SITE: # 12 CANTERBURY
WATER SUPPLY: On-Site Well ___ Comm. Well ___ Public ___ Other ✓ EVAL. METHOD: Auger Boring ✓ ~~Pit~~ ___ Cut ___

PROFILE #	.1940 LANDSCP POS./ SLOPE %	HORIZON DEPTH (IN.)	.1941 (a)(1) TEXTURE	.1941 (a)(2) STRUCTURE	.1941 (a)(3) MINEROLOGY		
1	L 4-6%	0-30	C	ABK	1:1 / FI	.1942 WETNES CONDITION	S -
		30-48	C	WSBK	1:1 / FR	.1943/.1956 SAPROLITE	S - (MICACEOUS)
						.1944 RESTRICTIVE HORIZON	S -
						.1948 PROFILE CLASSIFICATION	PS -
						PROFILE LTAR	0.33
2	L 4-6%	0-30	C	ABK	1:1 / FI	1942 WETNES CONDITION	S -
		30-32	C/SAP	GR	1:1 / FR	.1943/.1956 SAPROLITE	PS - (MICACEOUS)
		32-48	C	WSBK	1:1 / FR	.1944 RESTRICTIVE HORIZON	S -
						.1948 PROFILE CLASSIFICATION	PS -
						PROFILE LTAR	0.33 GRD / FR
3						.1942 WETNESS CONDITION	-
						.1943/.1956 SAPROLITE	-
						.1944 RESTRICTIVE HORIZON	-
						.1948 PROFILE CLASSIFICATION	-
						PROFILE LTAR	-
4						.1942 WETNESS CONDITION	-
						.1943/.1956 SAPROLITE	-
						.1944 RESTRICTIVE HORIZON	-
						.1948 PROFILE CLASSIFICATION	-
						PROFILE LTAR	-
5						.1942 WETNESS CONDITION	-
						.1943/.1956 SAPROLITE	-
						.1944 RESTRICTIVE HORIZON	-
						.1948 PROFILE CLASSIFICATION	-
						PROFILE LTAR	-

AVAILABLE SPACE (.1945) S SITE CLASSIFICATION (.1948): PS SITE LONG-TERM ACCEPTANCE RATE: 0.33 GRD/FR
OTHER FACTORS(.1946) NONE SYSTEM TYPE CONV. GRAVITY
EVALUATED BY: S. HEDRICK OTHER(S) PRESENT: TERRY O'BRIEN
COMMENTS:

DRAFT