DENR/DEH

ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: ___
COUNTY: ___

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Merle Loppy
ADDRESS: ___ APPLICATION DATE ___
PROPOSED FACILITY: 3bedroom PROPOSED DESIGN FLOW (.1949): 360gpd DATE EVALUATED: ___
LOCATION OF SITE: Meadow Oaks II #81 PROPERTY SIZE: ___
WATER SUPPLY: • Private • X Public • Well • Spring • Other ___ PROPERTY RECORDED: ___
EVALUATION METHOD: • Auger Boring • X Pit • Cut TYPE OF WASTEWATER: X Sewage • Industrial Process • Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	5-7%	0-5	Brsl gr	Frsssp	—	42"	common Inc sap	—	PS 0.3 – 0.35
		5-27	Rc sbk	Frsssp					
		27-42	Rclwsbk	Frsssp					
		42-58	lsap m w/clay Inc	Frsssp			PS		
2	5-7%	0-3	Brsclwsbk	Frsssp	—	46"	common Inc sap	—	PS 0.3 – 0.35
		3-26	Rc sbk	Frsssp					
		26-46	Rclwsbk	Frsssp					
		46-52	Slsap m w/clay Inc	Frsssp			PS		
3	5-7%	0-4	Brsclwsbk	Frsssp	—	58"	common Inc sap @ 36"	—	PS 0.3
		4-31	Rc sbk	Frsssp					
		31-58	Rclsbk	Frsssp					
4	5-7%	0-7	RBrsclwsbk	Frsssp	—	52"	Few Inc Sap @ 32"	—	PS 0.3
		7-38	Rc sbk/Mk	Frsssp					
		38-52	Rclwsbk	Frsssp					

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	600ft²	600ft²
System Type(s)	PPBPS	PPBPS
Site LTAR	0.3	0.3

OTHER FACTORS (.1946): ___
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: GM
OTHER(S) PRESENT: ___

COMMENTS: ___

DEPARTMENT OF ENVIRONMENT
AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

SOIL/SITE EVALUATION

(Continuation Sheet)

Sheet ____ of ____

PROPERTY ID #: _____
DATE OF EVALUATION: _____
COUNTY: _____

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	OTHER PROFILE FACTORS .1943 SOIL DEPTH	OTHER PROFILE FACTORS .1956 SAPRO CLASS	OTHER PROFILE FACTORS .1944 RESTR HORIZ	PROFILE CLASS & LTAR
5	5-7%	0-25	Bcsc/wsbk	Frsssp	—	53"	Few Inc sap @ 45"	—	PS 0.35
		25-53	Rc/wsbk	Frsssp					

COMMENTS: _____