DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM Mobile 902-0799

OWNER: Kent Nicholson APPLICANT: Kent Nicholson
ADDRESS: _____ APPLICATION DATE: 2-13-01 DATE EVALUATED: 3/22/01
PROPOSED FACILITY: _____ PROPOSED DESIGN FLOW (.1949): _____ PROPERTY SIZE: _____
LOCATION OF SITE: Hwy 158 @ (A) Meadow Oaks Subdivision, Lot 66 PROPERTY RECORDED: _____
WATER SUPPLY: ☐ Private ☒ Public ☐ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed
Meadow Oaks #66

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFIL CLASS & LTAR
1		0-8	scl		Dk Brn				PS .3
		8-24	cl f mic						
		24-36	cl sm f sbk						
		36-44	cl y mgy f sbk						
		44-48	Sap sandy cl						
2		0-3	scl						PS .3
		3-36	cl c mic						
		36-48	cl m mic Sap						
3		0-2	Sl						PS .4
		2-18	cl w sm mic						
		18-26	cl w sm						
		26-48	Sap Sandy L						
4		0-2	Scl						PS .3
		2-19	cl w com						
		19-36	cl w com						
		36-48	Sap						

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	PS	PS
System Type(s)	Conv & Pump	Pump
Site LTAR	.3	.3

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): _____
EVALUATED BY: Ben Robertson
OTHER(S) PRESENT: _____