No Copy on file

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System — G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Iredell County Rescue Squad. DATE 3-5-76 PERMIT NO. _____

PHONE: Business _____ Home _____


LOCATION Highway 115 N. Just beyond Chipley Ford Road. S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House ( ) Mobile Home ( ) Business ( ) Other Rescue Squad Headquarters

No. Bedrooms _____ No. Bathrooms _____
Garbage Disposal Unit Yes ( ) No ( )
Auto. Dishwasher Yes ( ) No ( )
Auto. Wash. Machine Yes ( ) No ( )
Site Suitable Yes ( ) No ( )
Lot Area _____

Character & Porosity of Soil Sandy Clay Loam
Percolation Rate _____
Topography Slope toward Highway
Depth to Water Table Low
Rock or other impervious formations None



Plot of System

Size of Tank 1250 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 750 Linear Ft. 300
Depth of Stone in Lines 10"
Water Supply: Individual (✓)
Public ( )

Installed by Hoke Septic Tank Co.
1 floor Drain.
2 Lines
Ditch 5 X 80
400 sq ft.

IMPROVEMENTS PERMIT BY _____

COMMENTS: Downspouts should be diverted away from Drainfields.

CERTIFICATE OF COMPLETION BY E. A. Stevenson DATE 3-5-76

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold