DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY ID #: _____
COUNTY: _____

Permit #10193

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Chris Weatherman (704) 252-0841 cell phone
APPLICANT: Same
ADDRESS: _____
APPLICATION DATE: _____
DATE EVALUATED: _____
PROPOSED FACILITY: 3BR
PROPOSED DESIGN FLOW (.1949): 360
PROPERTY SIZE: 4.66 Acres
LOCATION OF SITE: _____
PROPERTY RECORDED: _____
WATER SUPPLY: ☒ Private ☒ Public ☐ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

Moore Oaks Dr Lot #91

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFIL CLASS & LTAR
1	4% Linear	0-8	scl	ssp SEH					PS .25
		8-14	cl sbk	fi sp SEH					
		14-38	c AG bk	fi sp SEH					
		38-49	sl 4% c.f						
2	4% Linear	0-6	scl	ssp SEH					PS .25
		6-12	cl sbk	fi ssp SEH					
		12-38	c AG bk	vfi sp SEH					
		38-49	cl sbk	fi sp SEH					
3	3% Linear	0-6	scl	fr ssp NEH					PS .30
		6-10	c AG bk	fi sp SEH					
		10-22	cl sbk	fi sp					
		22-32	cl w/ trp wetbk	fr ssp SEH					
		32-48	Sap w/ clay inc.	fr ns/p NEH					
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	PS	PS
System Type(s)	Trench Conv.	Trench LPP
Site LTAR	.30	.25

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): _____
EVALUATED BY: Bill Johnson
OTHER(S) PRESENT: _____