IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System — G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR James Deal DATE 25 Jul 74 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Hwy 115 - Bank House on R. past McNeil Oil Co. across rd. from Mammoth Mart. S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms _____ No. Bathrooms _____

Garbage Disposal Unit	Yes ( )	No ( )	
Auto. Dishwasher	Yes ( )	No ( )	
Auto. Wash. Machine	Yes ( )	No ( )	
Site Suitable	Yes (✓)	No ( )	

Lot Area _____

Character & Porosity of Soil Sandy Clay.
Percolation Rate 30"
Topography Hilly slope to rear of house
Depth to Water Table 4'
Rock or other impervious formations None



Plot of System Hwy. 115

Size of Tank Ryan Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 630 Linear Ft. 210
Depth of Stone in Lines 12"
Water Supply: Individual (✓)
Public ( )

Installed by Henry Lyons

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Billy Howard DATE 25 Jul 74

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold