IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Smith Bldg. Co. DATE 11-30-77 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Chestnut St.

S. R. No. _____

SUBDIVISION NAME Beverly Heights LOT NO. 63 SECTION OR BLOCK NO. _____


House (✓) Mobile Home ( ) Business ( ) Other _____ Rev. Santee

No. Bedrooms 3 No. Bathrooms 1½

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes ( )	No ( )	
Auto. Wash. Machine	Yes ( )	No ( )	
Site Suitable	Yes ( )	No ( )	

Lot Area _____

Character & Porosity of Soil Red Clay -
Percolation Rate Slow - Mod
Topography 6 - 10% Slopes W.
Depth to Water Table ---
Rock or other impervious formations None



Plot of System

Size of Tank 1250 Gals.
Nitrification Field:
No. of Lines 4
Sq. Ft. 726 Linear Ft. 242
Depth of Stone in Lines 16"
Water Supply: Individual ( )
Public (✓)

Installed by Paul Page

IMPROVEMENTS PERMIT BY _____

COMMENTS: Limited Area for Septic Tank System - Sandy Type Clay

CERTIFICATE OF COMPLETION BY Gilmer Fox Jr. DATE 11/30/77

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold