IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System — G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Gaither Bldg Co. DATE 4-5-78 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Chestnut St.

SUBDIVISION NAME Beverly Heights S. R. No. _____

LOT NO. 62 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes (7)	No ( )	
Auto. Dishwasher	Yes (4)	No ( )	
Auto. Wash. Machine	Yes (4)	No ( )	
Site Suitable	Yes (6)	No ( )	

Lot Area _____


Character & Porosity of Soil Clay

Percolation Rate _____

Topography Gt. Slope

Depth to Water Table _____

Rock or other impervious formations Stone



Plot of System

Size of Tank 1250 Gals.

Nitrification Field:

No. of Lines 3

Sq. Ft. 250 Linear Ft. 250

Depth of Stone in Lines 16"

Water Supply: Individual ( )

Public (✓)

Installed by Gaither

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY _____ DATE 4/5/78

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold