IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR William W. Redman DATE 12/15/78 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Chipley Ford Rd.
House back off of road S. R. No. _____


SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House (+) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 4 No. Bathrooms 3

Garbage Disposal Unit	Yes ( )	No (+)	Character & Porosity of Soil	Prob Suitable
Auto. Dishwasher	Yes (+)	No ( )	Percolation Rate	
Auto. Wash. Machine	Yes (+)	No ( )	Topography	2-6% Slope
Site Suitable	Yes (+)	No ( )	Depth to Water Table	Low
			Rock or other impervious formations	None

Lot Area 60 Acres



Plot of System

Size of Tank 1250 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 900 Linear Ft. 300
Depth of Stone in Lines 16"
Water Supply: Individual (+)
Public ( )

Installed by Culberson

IMPROVEMENTS PERMIT BY _____

COMMENTS: Backfill with Clean dirt No roots or other trash to be in ditch. Should have More fall from Tank to Distribution box

CERTIFICATE OF COMPLETION BY E. A. Stevenson DATE 12/18/78

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold