HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY I.D.#: 10A-A-20 (9)
PROPERTY RECORDED:
COUNTY: IREDELL

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: WADE C. LEVAN OWNER: ✓ AGENT: PHONE: 876-6002
ADDRESS: 1015 NIXON ROAD APPLICATION DATE: 10/27/93 DATE EVALUATED: 10/27/93
STVL, NC 28677 PROPOSED FACILITY: 3BR HOUSE
PROPERTY SIZE: 1.39 AC
LOCATION OF SITE: LOT #9 MEADOW OAKS S/D
WATER SUPPLY: On-Site Well___ Comm. Well___ Public ✓ Other___ EVAL. METHOD: Auger Boring ✓ Pit___ Cut___

PROFILE #	.1940 LANDSCP POS./ SLOPE %	HORIZON DEPTH (IN.)	.1941 (a)(1) TEXTURE	.1941 (a)(2) STRUCTURE	.1941 (a)(3) MINEROLOGY	
1	S 2-4%	0-6	SC	GR	1:1 / VFR	.1942 WETNES CONDITION S
		6-36	C	SBK	1:1 / FR	.1943/.1956 SAPROLITE S
		36-48	SC	WSBK	1:1 / FR	.1944 RESTRICTIVE HORIZON S
						.1948 PROFILE CLASSIFICATION PS
						PROFILE LTAR 0.35 GPD/FT²
2						.1942 WETNES CONDITION
						.1943/.1956 SAPROLITE
						.1944 RESTRICTIVE HORIZON
						.1948 PROFILE CLASSIFICATION
						PROFILE LTAR
3						.1942 WETNESS CONDITION
						.1943/.1956 SAPROLITE
						.1944 RESTRICTIVE HORIZON
						.1948 PROFILE CLASSIFICATION
						PROFILE LTAR
4						.1942 WETNESS CONDITION
						.1943/.1956 SAPROLITE
						.1944 RESTRICTIVE HORIZON
						.1948 PROFILE CLASSIFICATION
						PROFILE LTAR
5						.1942 WETNESS CONDITION
						.1943/.1956 SAPROLITE
						.1944 RESTRICTIVE HORIZON
						.1948 PROFILE CLASSIFICATION
						PROFILE LTAR

AVAILABLE SPACE (.1945) 5 SITE CLASSIFICATION (.1948): PS SITE LONG-TERM ACCEPTANCE RATE: 0.35 GPD/FT²
OTHER FACTORS(.1946) NONE SYSTEM TYPE CONV. GRAVITY
EVALUATED BY: STEVE HENDRICK OTHER(S) PRESENT: WADE LEVAN
COMMENTS:

DRAFT