IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Guthrie Bldg Co. written on. DATE 7-5-78 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Chestnut St. _____

_____ S. R. No. _____

SUBDIVISION NAME Beverly Heights LOT NO. 64 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit Yes ( ) No (✓)

Auto. Dishwasher Yes (✓) No ( )

Auto. Wash. Machine Yes (✓) No ( )

Site Suitable Yes (✓) No ( )

Lot Area _____


Character & Porosity of Soil Clay

Percolation Rate 5 to 6

Topography Level

Depth to Water Table 5 ft

Rock or other impervious formations None



Plot of System

Size of Tank 1250 Gals.

Nitrification Field:

No. of Lines 3

Sq. Ft. 256 Linear Ft. 252

Depth of Stone in Lines 16"

Water Supply: Individual ( )

Public (✓)

Installed by Guthrie Bldg Co
Dave Frye

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Glenn Fox Jr. DATE 7/5/78

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold