IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System — G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Gaither Bldg. Co. DATE 10/13/76 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Chestnut Street

S. R. No. _____


SUBDIVISION NAME Beverly Heights LOT NO. 95 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	Red Clay	
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	more	
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	slope to rear	
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	more	
			Rock or other impervious formations	none observed	

Lot Area 170 X 100



Plot of System

Size of Tank 1250 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 625 Linear Ft. 250
Depth of Stone in Lines 10"

Water Supply: Individual ( )
Public (✓)

Installed by Sam Gaither

IMPROVEMENTS PERMIT BY Glenn Fox, Jr.

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Charles T. Hyatt DATE 10/13/76

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold