IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Smithey Bldg. Co. DATE 4-29-77 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Chestnut St.

S. R. No. _____


SUBDIVISION NAME Beverly Heights LOT NO. 60 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	LFBz
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	Good
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	2-6% Slope
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	none
			Rock or other impervious formations	none

Lot Area 100 x 200 Approx



Size of Tank 1250 Gals.

Nitrification Field:

No. of Lines 3

Sq. Ft. 625 Linear Ft. 250

Depth of Stone in Lines 10"

Water Supply: Individual ( )

Public (✓)

Installed by Smithey Bldg. Co.

To - City of Statesville
Engr. Dept.

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Glenn Fox Jr. DATE 4/29/77

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold