IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Boan Builders DATE 3/30/79 PERMIT NO. _____

PHONE: Business 873-1735 Home _____

LOCATION Past Arts & Science Museum, 1st left, go 2 blocks, T.R 3rd Lot on left

S. R. No. _____

SUBDIVISION NAME Beverly Heights LOT NO. 93 SECTION OR BLOCK NO. _____


House (✓) Mobile Home ( ) Business ( ) Other Addition

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit Yes (✓) No ( )
Auto. Dishwasher Yes (✓) No ( )
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )

Character & Porosity of Soil Coil Clay Loam
Percolation Rate 60 min/inch
Topography 2 to 4% Slope
Depth to Water Table 10'+
Rock or other impervious formations none

Lot Area 17,000 sq ft



Plot of System

Size of Tank 1250 Gals.
Nitrification Field:
No. of Lines 2
Sq. Ft. 750 Linear Ft. 250
Depth of Stone in Lines 10"
Water Supply: Individual ( )
Public (✓)

Installed by Hoke Septic Tank Co.

IMPROVEMENTS PERMIT BY J. C. Moore

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Andrew E. Carey DATE 3/30/79

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold