IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Tommy Johnson DATE 12-19-79 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Museum Drive Cross Creek TL on Beverly Drive 2nd St. TR 2nd lot on left S. R. No. _____


SUBDIVISION NAME Beverly Heights LOT NO. 59 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	Cecil Sandy clay
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	80 MPI
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	2 to 6%
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	10'+
			Rock or other impervious formations	none

Lot Area 15,000 sq'



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 2
Sq. Ft. 750 Linear Ft. 250
Depth of Stone in Lines 18"

Water Supply: Individual ( )
Public (✓)

Installed by OK Excavating

IMPROVEMENTS PERMIT BY L. C. Moore

COMMENTS: landscape so that surface water will not stand over Tank or lines

CERTIFICATE OF COMPLETION BY L. C. Moore DATE 12-19-79

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold