IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Gaither Building Co. DATE 3-15-79 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Museum Rd TL on Rd 1950 (Chestnut drive) before ent TR 3rd house on right. S. R. No. _____


SUBDIVISION NAME Beverly Heights LOT NO. 172 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	Cecil clay loam	
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	90 min/inch	
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	4% Slope	
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	10'+	
			Rock or other impervious formations	none	

Lot Area 1/2 acre



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 2
Sq. Ft. 750 Linear Ft. 250
Depth of Stone in Lines 10"
Water Supply: Individual ( )
Public (✓)

Installed by Paul Frye

IMPROVEMENTS PERMIT BY J. C. Moore

COMMENTS: _____

CERTIFICATE OF COMPLETION BY J. C. Moore DATE 3-15-79

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold