IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System - G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR GAITHER BLDG. CO. DATE 7-31-74 PERMIT NO. _____

PHONE Business _____ Home _____

LOCATION BEVERLY HEIGHTS - CHESTNUT ST.

S. R. No. _____

SUBDIVISION NAME BEVERLY HEIGHTS LOT NO. 169 SECTION OR BLOCK NO. _____


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit Yes ( ) No (✓)
Auto. Dishwasher Yes (✓) No ( )
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )

Lot Area 13,000

Character & Porosity of Soil TIGHT RED CLAY -
Percolation Rate 1" - 60 min -
Topography SLIGHT SLOPE TO FRONT
Depth to Water Table _____
Rock or other impervious formations NONE



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 6
Sq. Ft. 625 Linear Ft. 250
Depth of Stone in Lines 10"
Water Supply: Individual ( )
Public (✓)

Installed by Gaither Bldg. Co.

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY _____ DATE 7/31/74

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold