IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System — G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Gaither Bldg. Co DATE 1-22-76 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Chestnut St.

S. R. No. _____


SUBDIVISION NAME Beverly Heights LOT NO. 97 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	Cecil Clay	
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	1" — 60 min	
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	Slope to back	
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	25+	
			Rock or other impervious formations	none	

Lot Area 100 X 170



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 625 Linear Ft. 250
Depth of Stone in Lines 10"
Water Supply: Individual ( )
Public (✓)

Installed by Gaither Bldg. Co.

IMPROVEMENTS PERMIT BY _____

COMMENTS: drain field crowds property line on west - should be 10 ft. - Not installed as designed on improvements permit.

CERTIFICATE OF COMPLETION BY Glenn Ford Jr. DATE 3/22/76

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold