IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Gaither Bldg Co. Haynes DATE 3-6-75 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Chestnut St. Beverly Heights – _____ S. R. No. _____


SUBDIVISION NAME Beverly Heights LOT NO. 166 167 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes (✓)	No ( )	Character & Porosity of Soil	Red Clay
Auto. Dishwasher	Yes ( )	No (✓)	Percolation Rate	
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	Slope to Rt rear
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	
			Rock or other impervious formations	none

Lot Area 100 X 205 = 20,500 ± ?



Plot of System

Size of Tank 1250 Gals.

Nitrification Field:
No. of Lines 5
Sq. Ft. 625 Linear Ft. 250
Depth of Stone in Lines 18"

Water Supply: Individual ( )
Public (✓)

Installed by Gaither Bldg. Co.

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Glenn Foard Jr. DATE 3/6/75

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold