IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Gaither Bldg. Co. DATE 8-19-75 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Chestnut St. Beverly Heights

SUBDIVISION NAME Beverly Heights LOT NO. 165 SECTION OR BLOCK NO. _____ S. R. No. _____


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes (✓)	No ( )	
Auto. Dishwasher	Yes (✓)	No ( )	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Lot Area 110 F - 130 R 120 Deep

Character & Porosity of Soil Red Clay
Percolation Rate none
Topography Slopeth Rt ain
Depth to Water Table none
Rock or other impervious formations none



Plot of System

Size of Tank 1250 Gals.
Nitrification Field:
No. of Lines 4
Sq. Ft. 750 Linear Ft. 500
Depth of Stone in Lines 10"
Water Supply: Individual ( )
Public (✓)

Installed by Gaither Bldg Co.

IMPROVEMENTS PERMIT BY _____

COMMENTS: House construction not started when septic tank system installed

CERTIFICATE OF COMPLETION BY Glenn Todd DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold