IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System — G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Howard Englebert DATE 11/13/78 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 1701 Kenmore Dr. - T.R. off Cagley Ford Rd to Mocksville Rd, T.R. on 1948, 1st house on Rt. S. R. No. _____

SUBDIVISION NAME Beverly Heights LOT NO. _____ SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____


No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes (✓)	No ( )	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Lot Area ½ acre

Character & Porosity of Soil Loyd Clay
Percolation Rate 60-min finish
Topography 2-4% slope
Depth to Water Table 10± ft
Rock or other impervious formations none

Repair



Plot of System

Size of Tank existing Gals.
Nitrification Field:
No. of Lines 2
Sq. Ft. 300 Linear Ft. 150
Depth of Stone in Lines 16"
Water Supply: Individual ( )
Public (✓)

Installed by Hoke Septic Tank Co.

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Andrew E. Causey DATE 11/13/78

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold