IREDELL COUNTY HEALTH DEPARTMENT
Phone 1164

County Building — Statesville, N. C.

PERMIT TO INSTALL SEPTIC TANK

Permit No. 641 — Permit Date 6-16- 1942

Owner N. C. Dairies Corp. — Address Old National Rd

Tenant " " Grocery — Address " "

Installed by Clyde Hoke — Address Statesville N.C.

Location of property off National Rd - corner of Pistol Range Rd

Kind of tank Concrete — Capacity 800 — Length of trench 200 '


NOTIFY HEALTH DEPARTMENT AT LEAST EIGHT HOURS BEFORE TANK IS TO BE INSPECTED

There must be at least 200 feet of tile in line, with cinder pit at end.

Final Inspection 6-16-48 194 — Approved (✓) — Disapproved ( )

Remarks: Tea room, Tourist cabins, Service station, Cafe, Store and Church

First five feet of line from outlet should be of cast iron soil pipe.



Sketch of tank and line showing distance from dwelling and well on subject property and on adjoining property.

H. E. Verble
Sanitarian.