IREDELL COUNTY HEALTH DEPARTMENT

County Building | Phone 1164 | Statesville, N. C.

PERMIT TO INSTALL SEPTIC TANK

Permit No. _____ Permit Date _____ 194___

Owner Sam Gaither Address _____

Tenant ~~empty~~ Address _____

Installed by Parkers Address Mooresville, Rt 2

Location of Property Hartness Road 1800 yd

Kind of Tank Concrete Capacity ~~1000~~ Length of trench 225 3" x 3"

NOTIFY HEALTH DEPARTMENT AT LEAST EIGHT HOURS BEFORE TANK IS TO BE INSPECTED delet

There must be at least 200 feet of tile in line, with cinder pit at end.

Final Inspection June 1 1955 Approved (X) Disapproved ( )

Remarks: Approved for automatic dishwasher & disposal unit

First five feet of line from outlet should be of cast iron soil pipe.



Harry G. Isenhour

Sanitarian

Sketch of tank and line showing distance from dwelling and well on subject property and on adjoining property.