IREDELL COUNTY HEALTH DEPARTMENT

County Building | Phone 1164 | Statesville, N. C.

PERMIT TO INSTALL SEPTIC TANK

Permit No. _____ Permit Date _____ 194___

Owner Sam Gaither Address Statesville

Tenant [illegible] Address [illegible]

Installed by Parker Bros Address pt. 2 Mooresville

Location of Property Hartness Road

Kind of Tank _____ Capacity 1450 Length of trench 225 - 30" x 30"


NOTIFY HEALTH DEPARTMENT AT LEAST EIGHT HOURS BEFORE TANK IS TO BE INSPECTED

There must be at least 200 feet of tile in line, with cinder pit at end.

Final Inspection June 1 1945 Approved (X) Disapproved ( )

Remarks: Approved for septic tank and disposal field.

First five feet of line from outlet should be of cast iron soil pipe.



Henry D. Jolliman
Sanitarian

Sketch of tank and line showing distance from dwelling and well on subject property and on adjoining property.