DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet 1 of 1
PROPERTY ID #: 9736011721
COUNTY: IREDELL

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: AUSTIN & AUSTIN BLDG. APPLICANT: SAME
ADDRESS: 120 CHECKERS LANE, STVL, NC APPLICATION DATE: 6-11-98 DATE EVALUATED: 6-30-98
PROPOSED FACILITY: 3BR w/ C.S. PROPOSED DESIGN FLOW (.1949): 360 PROPERTY SIZE: 105' X 235'
LOCATION OF SITE: NC 115 N, TL SCOTTS CREEK, TL OLD WILKES, 2ND RIGHT PROPERTY RECORDED: _____
WATER SUPPLY: ☐ Private ☑ Public ☐ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☐ Auger Boring ☑ Pit ☐ Cut
TYPE OF WASTEWATER: ☑ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	L 8%	0-4"	GR SBK / SCL	VFR / NEXP	—	—	—	—	PS 0.3
		4-12"	SM SBK / SC	FR / NEXP					
		12-36	SF SBK / C	FI / NEXP					
		36-42	WFSBK WFABL / C	FI / NEXP					
		42-48	WFSBK / SAPROLITE SL	FR / NEXP					
2									
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		
System Type(s)		
Site LTAR	0.3 (PS)	

OTHER FACTORS (.1946): NONE
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: STEVE HOPKINS / JEFF MORGAN
OTHER(S) PRESENT: CARRY & HARDING AUSTIN