IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR J. Ray Miller DATE 5-9-83 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 115 N - 12 on Old 115 - 1st Mobile Home on left past Scotts Farm Rd SR 1557 S. R. No. 1645

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 1½ Character & Porosity of Soil Lloyd - Iredell Sandy Loam

Garbage Disposal Unit Yes ( ) No (✓) Percolation Rate 5 Min per Inch


Auto. Dishwasher Yes ( ) No (✓) Topography 2 - 6 % Slope

Auto. Wash. Machine Yes (✓) No ( ) Depth to Water Table 16+

Site Suitable Yes (✓) No ( ) Rock or other impervious formations None

Lot Area Adequate

___ Basement with Plumbing ___ Basement without Plumbing ✓ No Basement



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 2

Sq. Ft. 720 Linear Ft. 240

Depth of Stone in Lines 12"

Water Supply: Individual (✓)

Public ( )

Installed by J. Tom Hartness

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

3 x 120

IMPROVEMENTS PERMIT BY _____

3 x 120

COMMENTS: _____

CERTIFICATE OF COMPLETION BY _____ DATE 5/9/83

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy Pink Owner's Copy: Gold

OCT. 26, 1990 9:59