IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR George Mahaffey Sr. DATE 4-17-74 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Hwy # 115 N. House on L. About ½ Mile before you get to Road 1959. Near Wilsons Store S. R. No. _____


SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	Red Clay	
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	No Perk Test	
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	Slight Slope to Rock Low	
Site Suitable	Yes (✓)	No ( )	Depth to Water Table		
			Rock or other impervious formations	None	

Lot Area 26000 sq ft.



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 600 Linear Ft. 240+
Depth of Stone in Lines 10"
Water Supply: Individual (✓)
Public ( )

Installed by Lackey Bro.

IMPROVEMENTS PERMIT BY E. A. Stevenson

COMMENTS: House under Construction Prior to Dec. 5- 1973

CERTIFICATE OF COMPLETION BY E. A. Stevenson DATE 4-17-74

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold