HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY I.D.#: 10D-A-19
PROPERTY RECORDED:
COUNTY: IREDELL

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: HERITAGE BLDG CO. OWNER: AGENT: ✓ PHONE: 528-6699
ADDRESS: RT. 10, BOX 177-A APPLICATION DATE: 12/1/93 DATE EVALUATED: 12/1/93
STVL, NC 28677 PROPOSED FACILITY: 3 BR HOUSE
PROPERTY SIZE: 0.686 AC
LOCATION OF SITE: NC 115 N, TR SULLIVAN FARM RD, TR MEADOW OAK DR, 8TH LOT ON (R)
WATER SUPPLY: On-Site Well ___ Comm. Well ___ Public ___ Other ✓ EVAL. METHOD: Auger Boring ___ Pit ✓ Cut ___

PROFILE #	.1940 LANDSCP POS SLOPE %	HORIZON DEPTH (IN)	.1941 (a)(1) TEXTURE	.1941 (a)(2) STRUCTURE	.1941 (a)(3) MINEROLOGY	
1	N 4-6%	0-10	C	ABK	1:1 / FR	.1942 WETNESS CONDITION S
		10-32	C	SBK	1:1 / FR	.1943/.1956 SAPROLITE S
		32-48	SC	SBK	1:1 / FR	.1944 RESTRICTIVE HORIZON S
						.1948 PROFILE CLASSIFICATION PS
						PROFILE LTAR 0.35 GPD/FT2
2						1942 WETNESS CONDITION
						1943/.1956 SAPROLITE
						.1944 RESTRICTIVE HORIZON
						1948 PROFILE CLASSIFICATION
						PROFILE LTAR
3						.1942 WETNESS CONDITION
						.1943/.1956 SAPROLITE
						.1944 RESTRICTIVE HORIZON
						.1948 PROFILE CLASSIFICATION
						PROFILE LTAR
4						.1942 WETNESS CONDITION
						.1943/.1956 SAPROLITE
						.1944 RESTRICTIVE HORIZON
						.1948 PROFILE CLASSIFICATION
						PROFILE LTAR
5						.1942 WETNESS CONDITION
						.1943/.1956 SAPROLITE
						.1944 RESTRICTIVE HORIZON
						.1948 PROFILE CLASSIFICATION
						PROFILE LTAR

AVAILABLE SPACE (.1945) S SITE CLASSIFICATION (.1948): PS SITE LONG-TERM ACCEPTANCE RATE: 0.35 GPD/FT2
OTHER FACTORS(.1946) NONE SYSTEM TYPE CONV. GRAVITY
EVALUATED BY: S. HEDRICK OTHER(S) PRESENT: RICK DYSON
COMMENTS:

DRAFT