HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY I.D.#: 10D-1-A-23
PROPERTY RECORDED:
COUNTY: IREDELL

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: RICHARD O. CAMPBELL OWNER: AGENT: ✓ PHONE: 528-6860
ADDRESS: RT. 1, BOX 102-F APPLICATION DATE: 5/12/99 DATE EVALUATED: 5/12/99
TROUTMAN, NC 28166 PROPOSED FACILITY: 3BR HOUSE
PROPERTY SIZE: 130' x 230'
LOCATION OF SITE: #23 MEADOW OAKS
WATER SUPPLY: On-Site Well___ Comm. Well___ Public ✓ Other___ EVAL. METHOD: Auger Boring ✓ Pit___ Cut___

PROFILE #	.1940 LANDSCP POS./ SLOPE %	HORIZON DEPTH (IN.)	.1941 (a)(1) TEXTURE	(a)(2) STRUCTURE	(a)(3) MINEROLOGY		
1	H 8%	0-4	SC	GR	1:1 / FR	.1942 WETNES CONDITION	S
		4-36	C	ABK	1:1 / FI	.1943/.1956 SAPROLITE	S
		36-48	C/SAP	WSBK	1:1 / FR	.1944 RESTRICTIVE HORIZON	S
						.1948 PROFILE CLASSIFICATION	PS
						PROFILE LTAR	0.33 GPD/FT²
2	H 6%	0-6	SC	GR	1:1 / FR	.1942 WETNES CONDITION	S
		6-40	C	ABK	1:1 / FI	.1943/.1956 SAPROLITE	S
		40-48	C/SAP	WSBK	1:1 / FR	.1944 RESTRICTIVE HORIZON	S
						.1948 PROFILE CLASSIFICATION	PS
						PROFILE LTAR	0.33 GPD/FT²
3						.1942 WETNESS CONDITION	
						.1943/.1956 SAPROLITE	
						.1944 RESTRICTIVE HORIZON	
						.1948 PROFILE CLASSIFICATION	
						PROFILE LTAR	
4						.1942 WETNESS CONDITION	
						.1943/.1956 SAPROLITE	
						.1944 RESTRICTIVE HORIZON	
						.1948 PROFILE CLASSIFICATION	
						PROFILE LTAR	
5						.1942 WETNESS CONDITION	
						.1943/.1956 SAPROLITE	
						.1944 RESTRICTIVE HORIZON	
						.1948 PROFILE CLASSIFICATION	
						PROFILE LTAR	

AVAILABLE SPACE (.1945) S SITE CLASSIFICATION (.1948): PS SITE LONG-TERM ACCEPTANCE RATE: 0.33 GPD/FT²
OTHER FACTORS(.1946) NONE SYSTEM TYPE CONV. GRAVITY
EVALUATED BY: S. HEDRICK OTHER(S) PRESENT: RICK CAMPBELL
COMMENTS:

DRAFT