DEPARTMENT OF ENVIRONMENT, HEALTH & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

DRAFT

SHEET 1 OF 1
PROPERTY I.D.#: 10D-1-A-35
DATE: 9-14-95
COUNTY: IREDELL

SOIL SITE EVALUATION FOR ON-SITE WASTEWATER SYSTEM

APPLICANT: W & W SALES
ADDRESS: P.O. Box 5792
Stat, NC 28677

OWNER / AGENT / PHONE: 873-3568
APPLICATION DATE: 9-6-95 DATE EVALUATED 9-19-95
PROPOSED FACILITY: 3BR House
PROPERTY SIZE: 130' x 230'

LOCATION OF SITE: #35 MEADOW OAKS
WATER SUPPLY: On-site Well ___ Comm. Well ___ Public ___ Other ___ EVAL. METHOD: Auger Boring / Pit ___ Cut ___

PROFILE #	1940 LANDSCP POS./ SLOPE(%)	HORIZON DEPTH (IN.)	.1941 (a)(1) TEXTURE	.1941 (a)(2) STRUCTURE	.1941 (a)(3) MINEROLOGY	MATRIX COLOR	MOTTLE COLOR	OTHER PROFILE FACTORS
1	L	0-48	C	SBK	1:1/ FI			.1942 Wetness Cond. S
	2-4%							.1943 Depth/.1956 Sapr. S
								.1944 Restrictive Hori. S
								.1948 Profile Class. PS
								Profile LTAR 0.3
2								.1942 Wetness Cond. -
								.1943 Depth/.1956 Sapr. -
								.1944 Restrictive Hori. -
								.1948 Profile Class. -
								Profile LTAR -
3								.1942 Wetness Cond. -
								.1943 Depth/.1956 Sapr. -
								.1944 Restrictive Hori. -
								.1948 Profile Class. -
								Profile LTAR -
4								.1942 Wetness Cond. -
								.1943 Depth/.1956 Sapr. -
								.1944 Restrictive Hori. -
								.1948 Profile Class. -
								Profile LTAR -

AVAILABLE SPACE (.1945) S OTHER FACTORS (.1946) NONE SITE CLASSIFICATION (.1948) PS

SYSTEM TYPE CONV. GRAVITY LONG-TERM ACCEPTANCE RATE(S) 0.3 GPD/FT²

EVALUATED BY: S. HODNICK OTHER(S) PRESENT: MR. BENNY WILSON

COMMENTS: