HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY I.D.#: 10D-I-A-34
PROPERTY RECORDED:
COUNTY: IREDELL

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: SAMUEL SCOTT OWNER: AGENT: ✓ PHONE: 873-1391
ADDRESS: 2310 S. CHIPLEY FORD APPLICATION DATE: 8/22/94 DATE EVALUATED: 8/22/94
STVL, NC 28677 PROPOSED FACILITY: 3BR HOUSE
PROPERTY SIZE: 130' x 230'
LOCATION OF SITE: I-39 MEADOW OAKS
WATER SUPPLY: On-Site Well___ Comm. Well___ Public ___ Other___ EVAL. METHOD: Auger Boring ✓ Pit___ Cut___

PROFILE #	.1940 LANDSCP POS./ SLOPE %	HORIZON DEPTH (IN.)	.1941 (a)(1) TEXTURE	(a)(2) STRUCTURE	(a)(3) MINEROLOGY		
1	N 4%	0-8	SC	GR	1:1 / VFR	.1942 WETNES CONDITION	S
		8-38	C	W SBK	1:1 / FI/SP/SS	.1943/.1956 SAPROLITE	S
		38-48	SC	GR	1:1 / FR	.1944 RESTRICTIVE HORIZON	S
						.1948 PROFILE CLASSIFICATION	PS
						PROFILE LTAR	0.33 GPD/FT²
2	N 4%	0-10	SC	GR	1:1 / VFR	.1942 WETNES CONDITION	S
		10-36	C	W SBK	1:1 / FI/SS/SP	.1943/.1956 SAPROLITE	S
		36-48	SC	GR	1:1 / FR	.1944 RESTRICTIVE HORIZON	S
						.1948 PROFILE CLASSIFICATION	PS
						PROFILE LTAR	0.33
3						.1942 WETNESS CONDITION	-
						.1943/.1956 SAPROLITE	-
						.1944 RESTRICTIVE HORIZON	-
						.1948 PROFILE CLASSIFICATION	-
						PROFILE LTAR	-
4						.1942 WETNESS CONDITION	-
						.1943/.1956 SAPROLITE	-
						.1944 RESTRICTIVE HORIZON	-
						.1948 PROFILE CLASSIFICATION	-
						PROFILE LTAR	-
5						.1942 WETNESS CONDITION	-
						.1943/.1956 SAPROLITE	-
						.1944 RESTRICTIVE HORIZON	-
						.1948 PROFILE CLASSIFICATION	-
						PROFILE LTAR	-

AVAILABLE SPACE (.1945) S SITE CLASSIFICATION (.1948): PS SITE LONG-TERM ACCEPTANCE RATE: 0.33
OTHER FACTORS(.1946) NONE SYSTEM TYPE CONV. GRAVITY
EVALUATED BY: S. HEDRICK OTHER(S) PRESENT: DAVID YOUNTZ, ANDY YOUNTZ, PETE SCOTT
COMMENTS:

DRAFT