HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY I.D.#: 10D-T-A-31
PROPERTY RECORDED:
COUNTY: IREDELL

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: JEFFREY T. ELLIS OWNER: ✓ AGENT: PHONE: 878-6833
ADDRESS: RT. 15, 1 BOX 19 APPLICATION DATE: 3/4/94 DATE EVALUATED: 3/4/94
STVL, NC, 28677 PROPOSED FACILITY: 3BR HOUSE
PROPERTY SIZE: 130' x 230'
LOCATION OF SITE: MEADOW OAKS #31
WATER SUPPLY: On-Site Well___ Comm. Well___ Public___ Other ✓ EVAL. METHOD: Auger Boring ✓ Pit___ Cut___

PROFILE #	.1940 LANDSCP POS./ SLOPE %	HORIZON DEPTH (IN.)	.1941 (a)(1) TEXTURE	.1941 (a)(2) STRUCTURE	.1941 (a)(3) MINEROLOGY		
1	L 2%	0-48	C	SBK	1:1 / FI	.1942 WETNES CONDITION	S
						.1943/.1956 SAPROLITE	S
						.1944 RESTRICTIVE HORIZON	S
						.1948 PROFILE CLASSIFICATION	PS
						PROFILE LTAR	0.35
2	L 2%	0-48	C	SBK	1:1 / FI	.1942 WETNES CONDITION	S
						.1943/.1956 SAPROLITE	S
						.1944 RESTRICTIVE HORIZON	S
						.1948 PROFILE CLASSIFICATION	PS
						PROFILE LTAR	0.35
3						.1942 WETNESS CONDITION	-
						.1943/.1956 SAPROLITE	-
						.1944 RESTRICTIVE HORIZON	-
						.1948 PROFILE CLASSIFICATION	-
						PROFILE LTAR	-
4						.1942 WETNESS CONDITION	-
						.1943/.1956 SAPROLITE	-
						.1944 RESTRICTIVE HORIZON	-
						.1948 PROFILE CLASSIFICATION	-
						PROFILE LTAR	-
5						.1942 WETNESS CONDITION	-
						.1943/.1956 SAPROLITE	-
						.1944 RESTRICTIVE HORIZON	-
						.1948 PROFILE CLASSIFICATION	-
						PROFILE LTAR	-

AVAILABLE SPACE (.1945) S SITE CLASSIFICATION (.1948): PS SITE LONG-TERM ACCEPTANCE RATE: 0.35
OTHER FACTORS(.1946) NONE SYSTEM TYPE CONV. GRAVITY
EVALUATED BY: S. HENDRICK OTHER(S) PRESENT: DAVID YOUNTZ, ANDY YOUNTZ, EDDIE YOUNTZ, TODD ELLIS, WAYNE POPE
COMMENTS:

DRAFT