DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY ID #: 4736 40 5209
COUNTY: ROBESON

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: EARL LINDERMAN APPLICANT: DAVID BRADY
ADDRESS: 494 EUFOLA RD STVL, NC 28677 APPLICATION DATE: 1-16-01 DATE EVALUATED: 2-3-01
PROPOSED FACILITY: 4BR HOUSE PROPOSED DESIGN FLOW (.1949): 480 PROPERTY SIZE: 0.728 ACRE
LOCATION OF SITE: MEADOW OAKS I #5 PROPERTY RECORDED: _____
WATER SUPPLY: ☐ Private ☑ Public ☐ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☑ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☑ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	SLIGHT H 10%	0-48	SBK / C	FR / SEXP					PS 0.3
2	SLIGHT H 10%	0 48	SBK / C	FR / SEXP					PS 0 3
3	L 8%	0 48	SBK / C	FR / SEXP					PS 0 3
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	PS	PS
System Type(s)	III	IV
Site LTAR	0.3	0.3

OTHER FACTORS (.1946): NONE
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: S. HENDRICK
OTHER(S) PRESENT: DAVID BRADY