ADDRESS Samuel Scott APPLICATION DATE _____ DATE EVALUATED _____

PROPOSED FACILITY _____

PROPERTY SIZE _____

LOCATION OF SITE Lot 1 Ft Dobbs Farms

WATER SUPPLY: On-site Well ___ Other Well ___ Public ___ Other ___ EVAL METHOD: Auger Boring ___ Pit ___ Cut ___

PROFILE	1940 LANDSCP POS/ SLOPE(%)	HORIZON DEPTH (IN)	(1941) TEXTURE	(1942) STRUCTURE	(1951) MINERALOGY	MATRIX COLOR	MOTTLE COLOR	OTHER PROFILE FACTORS
Linear 1090		0 to 14	L	Gr				1942 Wetness Cond. N/A
		14 to 36	C	SBK	l.l			1943 Depth/ 1956 Sapr. N/A
		36 to 48	CL	weak SBK	l.l			1944 Restrictive Hori. N/A
								1948 Profile Class. PS
								Profile LTAR .33
Linear 1090		0 to 10	L	Gr				1942 Wetness Cond. N/A
		10 to 36	C	SBK	l.l			1943 Depth/ 1956 Sapr. N/A
		36 to 48	CL	weak SBK	l.l			1944 Restrictive Hori. N/A
								1948 Profile Class. PS
								Profile LTAR .33
								1942 Wetness Cond.
								1943 Depth/ 1956 Sapr.
								1944 Restrictive Hori.
								1948 Profile Class.
								Profile LTAR
								1942 Wetness Cond.
								1943 Depth/ 1956 Sapr.
								1944 Restrictive Hori.
								1948 Profile Class.
								Profile LTAR

ABSORBABLE SPACE (1945) Yes OTHER FACTORS (1946) _____ SITE CLASSIFICATION (1948) PS

SYSTEM TYPE conv. Gravity LONG-TERM ACCEPTANCE RATE(S) .33

EVALUATED BY: J.C. Moore OTHER(S) PRESENT _____

COMMENTS _____

001687