IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Hope Bro DATE 1/11/78 PERMIT NO.

PHONE: Business Home

LOCATION Chipley Park on Harriet Circle

S. R. No.

SUBDIVISION NAME Chipley Park LOT NO. 20 SECTION OR BLOCK NO.


House (✓) Mobile Home ( ) Business ( ) Other

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes ( )	No (✓)	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Lot Area 20000 sq ft

Character & Porosity of Soil Prof Suitable
Percolation Rate
Topography Slope
Depth to Water Table Low ?
Rock or other impervious formations None



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 756 Linear Ft. 252
Depth of Stone in Lines 16"
Water Supply: Individual ( )
Public (✓)

Installed by Hope Bro

IMPROVEMENTS PERMIT BY E. G. Stevenson

COMMENTS: Downspouts to be Piped away from septic tank and lines. Extra dirt to be filled in over lines Near end of ditch. No driving over lines.

CERTIFICATE OF COMPLETION BY E. G. Stevenson DATE 1/11/78

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold