IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System — G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Hope Bro DATE 1/18/78 PERMIT NO.

PHONE: Business Home

LOCATION Chipley Park on Hamit St.

S. R. No.

SUBDIVISION NAME Chipley Park LOT NO. 46 SECTION OR BLOCK NO.


House (✓) Mobile Home ( ) Business ( ) Other

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes ( )	No (✓)	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Character & Porosity of Soil Prov' Suitable
Percolation Rate
Topography Slope Low
Depth to Water Table
Rock or other impervious formations None

Lot Area 20,000 Sq ft



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 747 Linear Ft. 249
Depth of Stone in Lines 16" +
Water Supply: Individual ( )
Public (✓)

Installed by Hope Bro

IMPROVEMENTS PERMIT BY

COMMENTS: This system Put in in wet Weather. Yard to be graded so Water will run away and Not stand on lines. Down spouts and all surface Water Possible to be diverted away from lines System Not installed as Said Out.

CERTIFICATE OF COMPLETION BY E. B. Stevenson DATE 1/18/78

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold