IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Hope Bro. Builders DATE 7-10-74 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Chipley Park Sub Division Off of Chipley Ford Road S. R. No. _____

SUBDIVISION NAME Chipley Park LOT NO. 82 SECTION OR BLOCK NO. _____


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)
Auto. Dishwasher	Yes ( )	No (✓)
Auto. Wash. Machine	Yes (✓)	No ( )
Site Suitable	Yes (✓)	No ( )

Lot Area 20 000 Sq ft

Character & Porosity of Soil Red Clay
Percolation Rate No Perk Test
Topography Slight Slope
Depth to Water Table Low
Rock or other impervious formations None Noted



Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 630 Linear Ft. 252
Depth of Stone in Lines 10"
Water Supply: Individual ( )
Public (✓)

Installed by Hope Bro

IMPROVEMENTS PERMIT BY E. A. Stevenson

COMMENTS: Tank is dup - 24" Well Tile over opening into Tank. Lines are also dup first 40'.

CERTIFICATE OF COMPLETION BY E. A. Stevenson DATE 7-10-74

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold