IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Hope Bro DATE 11/6/78 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION _____

_____ S. R. No. _____

SUBDIVISION NAME Chipley Park LOT NO. 56 SECTION OR BLOCK NO. _____

House (✓ Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No ( )	
Auto. Dishwasher	Yes ( )	No ( )	
Auto. Wash. Machine	Yes ( )	No ( )	
Site Suitable	Yes ( )	No ( )	

Lot Area 120 X 300


Character & Porosity of Soil Prov Suitable

Percolation Rate _____

Topography Slope

Depth to Water Table Low

Rock or other impervious formations None



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 900 Linear Ft. 300
Depth of Stone in Lines 16"

Water Supply: Individual ( )
Public (✓

Installed by Hope Bro

IMPROVEMENTS PERMIT BY _____

COMMENTS: Lot to be graded so water will run away from Septic Tank + lines. Downspout next to tank to be run away from Tank.

CERTIFICATE OF COMPLETION BY E. A. Stevenson DATE 11/6/78

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold