IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Hope Bro DATE 11/14/78 PERMIT NO.

PHONE: Business Home

LOCATION

SUBDIVISION NAME Chipley Park LOT NO. 61 SECTION OR BLOCK NO. S. R. No.


House (✓) Mobile Home ( ) Business ( ) Other

No. Bedrooms 3 No. Bathrooms 1½

Garbage Disposal Unit	Yes ( )	No (✓)
Auto. Dishwasher	Yes ( )	No (✓)
Auto. Wash. Machine	Yes (✓)	No ( )
Site Suitable	Yes (✓)	No ( )

Lot Area 20 000 Sq ft

Character & Porosity of Soil Soil Suitable
Percolation Rate
Topography Slope
Depth to Water Table
Rock or other impervious formations None



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 900 Linear Ft. 300
Depth of Stone in Lines 16"
Water Supply: Individual ( )
Public (✓)

Installed by Hope Bro

IMPROVEMENTS PERMIT BY

COMMENTS: Downspouts to be Piped away from septic tank + lines.
Mr Johnson also approved this lot.

CERTIFICATE OF COMPLETION BY E. A. Stevenson DATE 11/14/78

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold