DEPARTMENT OF ENVIRONMENT,
HEALTH & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

DRAFT

PROPERTY I.D.#: _____
DATE: _____
COUNTY: _____

SOIL SITE EVALUATION FOR ON-SITE WASTEWATER SYSTEM

APPLICANT: Jack Borders OWNER__ AGENT:__ PHONE: _____
ADDRESS: _____ APPLICATION DATE: _____ DATE EVALUATED _____
PROPOSED FACILITY: _____
PROPERTY SIZE: _____
LOCATION OF SITE: _____
WATER SUPPLY: On-site Well____ Comm. Well____ Public____ Other_____ EVAL. METHOD: Auger Boring___ Pit___ Cut___

PROFILE #	.1940 LANDSCP POS / SLOPE(%)	HORIZON DEPTH (IN.)	.1941 (1) TEXTURE	.1941 (2) STRUCTURE	.1941 (3) MINERALOGY	MATRIX COLOR	MOTTLE COLOR	OTHER PROFILE FACTORS
1		0to4	L	GR				.1942 Wetness Cond. - N/A
		4to30	C	SBK	1:1			.1943 Depth/.1956 Sapr. - N/A
	linear 4to6%	30to48	CL	weak SBK	1:1			.1944 Restrictive Hori. - N/A
								.1948 Profile Class. - PS
								Profile LTAR - .35
2		0to4	L	GR				.1942 Wetness Cond. - N/A
	linear 4to6%	4to36	C	SBK	1:1			.1943 Depth/.1956 Sapr. - N/A
		36to48	CL	weak SBK	1:1			.1944 Restrictive Hori. - N/A
								.1948 Profile Class. - PS
								Profile LTAR - .35
3								.1942 Wetness Cond. -
								.1943 Depth/.1956 Sapr. -
								.1944 Restrictive Hori. -
								.1948 Profile Class. -
								Profile LTAR -
4								.1942 Wetness Cond. -
								.1943 Depth/.1956 Sapr. -
								.1944 Restrictive Hori. -
								.1948 Profile Class. -
								Profile LTAR -

AVAILABLE SPACE (.1945) yes OTHER FACTORS (.1946) _____ SITE CLASSIFICATION (.1948) PS

SYSTEM TYPE Conv. Gravity LONG-TERM ACCEPTANCE RATE(S) .35

EVALUATED BY: F. C. Moore OTHER(S) PRESENT: Jack Borders

COMMENTS: _____