DEPARTMENT OF ENVIRONMENT,
HEALTH & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

DRAFT

SHEET 1 OF 1
PROPERTY I.D.#: 10D-2-A-31
DATE: 1-30-96
COUNTY: IREDELL

SOIL SITE EVALUATION FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: TERRY LUTHER
ADDRESS: C/ BILLY SELF
P.O. BOX 1283
STVL, NC 28687

OWNER ✓ AGENT: PHONE: 873-9612
APPLICATION DATE: 1-4-96 DATE EVALUATED 1-30-96
PROPOSED FACILITY: 3BR HOUSE W/BSMT
PROPERTY SIZE: 2.163 ACRE

LOCATION OF SITE: FORT DOBBS # 31
WATER SUPPLY: On-site Well ___ Comm. Well ___ Public ✓ Other ___ EVAL. METHOD: Auger Boring ✓ Pit ___ Cut ___

PROFILE #	.1940 LANDSCP POS./ SLOPE(%)	HORIZON DEPTH (IN.)	.1941 (a)(1) TEXTURE	.1941 a)(2) STRUCTURE	.1941 (a)(3) MINEROLOGY	MATRIX COLOR	MOTTLE COLOR	OTHER PROFILE FACTORS
1	H	0-48	SC	SBK	1:1 / FI/FR			.1942 Wetness Cond. S
	8-10%							.1943 Depth/.1956 Sapr. S
								.1944 Restrictive Hori. S
								.1948 Profile Class. PS
								Profile LTAR 0.33
2	H	0-48	SC	SBK	1:1 / FI/FR			.1942 Wetness Cond. S
	10%							.1943 Depth/.1956 Sapr. S
								.1944 Restrictive Hori. S
								.1948 Profile Class. PS
								Profile LTAR 0.33
3								.1942 Wetness Cond. -
								.1943 Depth/.1956 Sapr. -
								.1944 Restrictive Hori. -
								.1948 Profile Class. -
								Profile LTAR -
4								.1942 Wetness Cond. -
								.1943 Depth/.1956 Sapr. -
								.1944 Restrictive Hori. -
								.1948 Profile Class. -
								Profile LTAR -

AVAILABLE SPACE (.1945) S OTHER FACTORS (.1946) NONE SITECLASSIFICATION (.1948) PS

SYSTEM TYPE CONV. GRAVITY LONG-TERMACCEPTANCE RATE(S) 0.33

EVALUATED BY: STEVE HEDRICK OTHER(S) PRESENT: BILLY SELF

COMMENTS:

0012S6