HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY I.D.#:
PROPERTY RECORDED:
COUNTY:

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: Charles D. Nantz OWNER: AGENT: PHONE:
ADDRESS: APPLICATION DATE: DATE EVALUATED: 10-6-94
PROPOSED FACILITY:
PROPERTY SIZE: 2.48 acres
LOCATION OF SITE:
WATER SUPPLY: On-Site Well ___ Comm. Well ___ Public ___ Other ___ EVAL. METHOD: Auger Boring ___ Pit ___ Cut ___

PROFILE #	.1940 LANDSCP POS./ SLOPE %	HORIZON DEPTH (IN.)	.1941 (a)(1) TEXTURE	.1941 (a)(2) STRUCTURE	.1941 (a)(3) MINEROLOGY		
1	linear 15%	0 to 10"	L	GR		.1942 WETNES CONDITION	N/A
		10 to 48	C	SBK	1:1	.1943/.1956 SAPROLITE	N/A
						.1944 RESTRICTIVE HORIZON	N/A
						.1948 PROFILE CLASSIFICATION	PS
						PROFILE LTAR	.35
2	linear 25%	0 to 12"	L	GR		.1942 WETNES CONDITION	N/A
		12 to 20	CL	SBK	1:1	.1943/.1956 SAPROLITE	N/A
		20 to 42	C	SBK	1:1	.1944 RESTRICTIVE HORIZON	N/A
		42 to 48	C	weak SBK	1:1	.1948 PROFILE CLASSIFICATION	PS
						PROFILE LTAR	.35
3	linear 20%	0 to 12"	L	GR		.1942 WETNESS CONDITION	N/A
		12 to 18	CL	SBK	1:1	.1943/.1956 SAPROLITE	N/A
		18 to 38	C	SBK	1:1	.1944 RESTRICTIVE HORIZON	N/A
		38 to 48	C	weak SBK	1:1	.1948 PROFILE CLASSIFICATION	PS
						PROFILE LTAR	.35
4	linear 15 to 18%	0 to 6	L	GR		.1942 WETNESS CONDITION	N/A
		6 to 36	C	SBK	1:1	.1943/.1956 SAPROLITE	N/A
		36 to 42	C	weak SBK	1:1	.1944 RESTRICTIVE HORIZON	N/A
		42 to 48	Transition			.1948 PROFILE CLASSIFICATION	PS
						PROFILE LTAR	.35
5						.1942 WETNESS CONDITION	
						.1943/.1956 SAPROLITE	
						.1944 RESTRICTIVE HORIZON	
						.1948 PROFILE CLASSIFICATION	
						PROFILE LTAR	

AVAILABLE SPACE (.1945) yes SITE CLASSIFICATION (.1948): PS SITE LONG-TERM ACCEPTANCE RATE: .35
OTHER FACTORS(.1946) SYSTEM TYPE Chuck Wantz
EVALUATED BY: L. C. Moore OTHER(S) PRESENT:
COMMENTS:

DRAFT