HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY I.D.#: ____ ____
PROPERTY RECORDED: ____
COUNTY: ____

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: Carl outen OWNER: AGENT: PHONE:
ADDRESS: APPLICATION DATE: DATE EVALUATED:
PROPOSED FACILITY:
PROPERTY SIZE:
LOCATION OF SITE:
WATER SUPPLY: On-Site Well ___ Comm. Well ___ Public ___ Other ___ EVAL. METHOD: Auger Boring ✓ Pit ___ Cut ___

PROFILE #	.1940 LANDSCP POS./ SLOPE %	HORIZON DEPTH (IN)	.1941 (a)(1) TEXTURE	.1941 (a)(2) STRUCTURE	.1941 (a)(3) MINEROLOGY	
1	linear 18%	0 to 12"	CL	GR		.1942 WETNES CONDITION - NA
		12"+	Saprolite + Rock			.1943/.1956 SAPROLITE - 12"
						.1944 RESTRICTIVE HORIZON - Rock 12"
						.1948 PROFILE CLASSIFICATION - U
						PROFILE LTAR -
2	Linear Ridge 20%	0 to 8"	CL	GR		.1942 WETNES CONDITION - N/A
		8 to 36	C	SBK	1:1	.1943/.1956 SAPROLITE - N/A
		36 to 48	C	weak SBK	1:1	.1944 RESTRICTIVE HORIZON - N/A
						.1948 PROFILE CLASSIFICATION - PS
						PROFILE LTAR - .35
3	Linear 18%	0 to 8"	CL	GR		.1942 WETNESS CONDITION - N/A
		8 to 36	C	SBK	1:1	.1943/.1956 SAPROLITE - N/A
		36 to 48	C	weak SBK	1:1	.1944 RESTRICTIVE HORIZON - N/A
						.1945 PROFILE CLASSIFICATION - PS
						PROFILE LTAR - .35
4	Linear 12%	0 to 8"	L	GR		.1942 WETNESS CONDITION - N/A
		8 to 40	C	SBK	1:1	.1943/.1956 SAPROLITE - N/A
		40 to 48	C	weak SBK	1:1	.1944 RESTRICTIVE HORIZON - N/A
						1948 PROFILE CLASSIFICATION - PS
						PROFILE LTAR - .35
5						.1942 WETNESS CONDITION -
						.1943/.1956 SAPROLITE -
						.1944 RESTRICTIVE HORIZON -
						.1948 PROFILE CLASSIFICATION -
						PROFILE LTAR -

AVAILABLE SPACE (.1945) yes SITE CLASSIFICATION (.1948): ~~AP~~ PS SITE LONG-TERM ACCEPTANCE RATE: .35
OTHER FACTORS(.1946) SYSTEM TYPE Conv. Gravity
EVALUATED BY: J.C. Moore OTHER(S) PRESENT: Carl Outen
COMMENTS:

DRAFT

00215