IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Frank Holland Builder DATE 1 Mar 77 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Hy 115 N to Chipley Ford Rd 6 M house on right pond 100 M 1926

S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 1½

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes ( )	No (✓)	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Lot Area 20,000± ft


Character & Porosity of Soil Coal Cly

Percolation Rate one

Topography 6-10% Slope

Depth to Water Table 2'

Rock or other impervious formations ∅



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 2

Sq. Ft. 625 Linear Ft. 250

Depth of Stone in Lines 10" plus

Water Supply: Individual ( )
Public (✓)

Installed by Eddie Young

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY W. M. Tolbert DATE 1 Mar 77

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold