IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Gloria B. May DATE 5-19-76 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Highway 115 N - TR on Chipley Ford Rd


SUBDIVISION NAME Mountain Acres S. R. No. _____

LOT NO. 28 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 1½

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	Red Clay
Auto. Dishwasher	Yes ( )	No (✓)	Percolation Rate	60
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	Slopes to Rd. Side & Rear
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	25+
Lot Area	Approx 19,897		Rock or other impervious formations	None



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 750 Linear Ft. 300
Depth of Stone in Lines 10"

Water Supply: Individual ( )
Public (✓)

Installed by Hicks Septic Tank Co.

IMPROVEMENTS PERMIT BY _____

COMMENTS: Lot Staked out at recommended location. Divert surface water away from septic tank system

CERTIFICATE OF COMPLETION BY Glenn Todd Jr. DATE 5/19/76

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold