IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System - G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Hope Bro DATE 1-29-75 PERMIT NO.

PHONE: Business Home

LOCATION Chipley Park

S. R. No.

SUBDIVISION NAME Chipley Park LOT NO. 29 SECTION OR BLOCK NO.


House (✓) Mobile Home ( ) Business ( ) Other

No. Bedrooms 3 No. Bathrooms 1½

Garbage Disposal Unit	Yes ( )	No (✓)
Auto. Dishwasher	Yes ( )	No (✓)
Auto. Wash. Machine	Yes (✓)	No ( )
Site Suitable	Yes (✓)	No ( )

Lot Area 20,000 sq. ft.

Character & Porosity of Soil Red Clay
Percolation Rate
Topography Slight Slope to front
Depth to Water Table Low
Rock or other impervious formations None



Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 625 Linear Ft. 250
Depth of Stone in Lines 10"
Water Supply: Individual ( )
Public (✓)

Installed by Hope Bro

IMPROVEMENTS PERMIT BY

COMMENTS: All surface water possible should be diverted away from Tank + Lines
Lines are Level.

CERTIFICATE OF COMPLETION BY E. G. Stevenson DATE 1-29-75

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold