IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System - G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Hope Bro DATE 11/10/78 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION _____

S. R. No. _____

SUBDIVISION NAME Chipley Park LOT NO. 62 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 1½

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes ( )	No (✓)	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Lot Area 20,000 SQ Ft


Character & Porosity of Soil Prev Suitable

Percolation Rate _____

Topography Slope

Depth to Water Table Low

Rock or other impervious formations None



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 900 Linear Ft. 300
Depth of Stone in Lines 16"

Water Supply: Individual ( )
Public (✓)

Installed by Hope Bro

IMPROVEMENTS PERMIT BY _____

COMMENTS: Downspouts and all surface water possible to be diverted away from septic tank & lines

CERTIFICATE OF COMPLETION BY E. A. Stevenson DATE 11/10/77

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold