02909

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System — G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Larry L. Jenkins DATE 10-9-86 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Chipley Ford Rd. - TR on Harriet Dr. - TR on Roseman Dr. - Down on RT

SUBDIVISION NAME Chipley Park S. R. No. _____


LOT NO. 323-326 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 1

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil Fine Sandy Loam
Auto. Dishwasher	Yes ( )	No (✓)	Percolation Rate Fast
Auto. Wash. Machine	Yes (✓)	No ( )	Topography Gently Sloping
Site Suitable	Yes (✓)	No ( )	Depth to Water Table 6'+
Lot Acc. OK 258			Rock or other impervious formations None

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 2

Sq. Ft. 870 Linear Ft. 290

Depth of Stone in Lines 12"

Water Supply: Individual ( )

Public (✓)

Installed by Jerry Thompson

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Glenn Fox DATE 10/2/86

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold